

Cc: [Redacted]
To: [Redacted] @tetrattech.com]
From: Wagner, Christine[/O=EXCHANGELABS/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=12068C1889924ECF96F692831F0C77D4-CWAGNE02]
Sent: Fri 6/11/2021 3:35:14 PM (UTC)
Subject: Re: Property 1 power line

Thanks [Redacted]
So I think we want to exclude any areas within 50 feet because of the ditch line

Thank you
Chris

On Jun 11, 2021, at 11:15 AM, [Redacted] @tetrattech.com> wrote:

Chris,

According to OSHA 1926.1408 (h) the right of way minimum clearance distance for high voltage overhead power lines over 500 kV is 35 feet. Dominion Energy high voltage power lines running along Bailey Memorial Hwy are 500 kV or greater. Dominion requires 30-50ft right of way clearance on those high voltage power lines.

We will work for our GIS people and get that added to the collector map today for you.

Thanks,
[Redacted]

[Redacted] | Environmental Scientist
[Redacted] @tetrattech.com

Tetra Tech | Complex World, Clear Solutions™ | Northeast Operations
1777 Sentry Parkway West, Bldg. 12 | Suite 102 | Blue Bell, PA 19422 | tetrattech.com